



Product Service

# Attestation of Conformity

No. N8A 101572 0003 Rev. 01

**Holder of Certificate:** **Philadelphia Solar Co.**  
Al Qastal Industrial Area, Air freight Road  
11814 Amman  
JORDAN

**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**[Mono Crystalline Silicon Photovoltaic (PV) Module(s)]**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 64290203011305B

**Date,** 2021-09-17

( Symbol Zhao )

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

# Attestation of Conformity

No. N8A 101572 0003 Rev. 01

**Model(s):**

PS-B72-xxx (xxx=420-455, in steps of 5);  
PS-B66-xxx (xxx=395-415, in steps of 5);  
PS-B60-xxx (xxx=350-380, in steps of 5);  
PS-B78(8)-xxx (xxx=430-445, in steps of 5);  
PS-B72(8)-xxx (xxx=400-415, in steps of 5);  
PS-B60(8)-xxx (xxx=330-345, in steps of 5);  
PS-M144(HCBF)-GG-xxxW (xxx=525-550, in steps of 5);  
PS-M132(HCBF)-GG-xxxW (xxx=480-505, in steps of 5);  
PS-M120(HCBF)-GG-xxxW (xxx=440-455, in steps of 5);  
PS-M108(HCBF)-GG-xxxW (xxx=390-410, in steps of 5).  
xxx stands for rated output power at STC.

PS-BXX-xxx, PS-BXX(8)-xxx and PS-MXXX(HCBF)-GG-xxxW series are bifacial modules. The "rated output power at STC" is generated only by front side.

**Parameters:**

Protection class:	Class II
Max. system voltage:	1500 V d.c.
Construction:	Framed, with Junction box, Cable and Connectors

**Tested according to:**

EN IEC 61730-1:2018  
EN IEC 61730-2:2018

Page 2 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.