

Certificate



Certificate no.

PV 722140003 01

License Holder:

Philadelphia Solar
Al Qastal Industrial Area 2,
Airfreight Road
11814 Amman
Jordan

Manufacturing Plant(s):

Refer to the latest revision of Appendix 2,
List of Factories.

Test report no.: USA-320440003.003

Client Reference: Mr. A. R. Shehadeh

Tested to: IEC 61215-1:2016, IEC 61215-1-1:2016,
IEC 61215-2:2016,
IEC 61730-1:2016,
IEC 61730-2:2016

Certified Product: Photovoltaic Modules

Model Designations:

PS-M72-xxx (xxx=350-425), PS-M60-xxx (xxx=275-330),
PS-P72-xxx (xxx=330-360), PS-P60-xxx (xxx=250-295)

Maximum System Voltage: 1500 V DC

Fire Classification Type: Type 1

Electrical ratings are provided at Standard Test Conditions (STC),
1000 W/m², AM 1.5 spectrum, 25°C cell temperature.

This certificate replaces PV 722040010 01.

Appendices: 1, 1-6 2, 1

Licensed Test Mark:



Date of Issue:

22 January 2021