



Product Service

CERTIFICATE

No. Z2 101572 0001 Rev. 00

Holder of Certificate: **Philadelphia Solar Co.**
Al Qastal Industrial Area, Air freight Road
11814 Amman
JORDAN

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262107701-00

Valid until: 2026-05-10

Date, 2021-05-25

(Zhulin Zhang)



CERTIFICATE

No. Z2 101572 0001 Rev. 00

Model(s):

PS-M60-xxx,xxx=330 to 350, in step of 5;
 PS-M72-xxx,xxx=395 to 420, in step of 5;
 PS-M60(HC)-xxx,xxx=345 to 380, in step of 5;
 PS-M72(HC)-xxx,xxx=415 to 460, in step of 5;
 xxx is standing for rated output power at STC

Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Construction:	Framed, with Junction box, cable and connector.
Fire Safety Class:	Class C according to UL790

Tested according to:

IEC 61215-1:2016
 EN 61215-1:2016
 IEC 61215-1-1:2016
 EN 61215-1-1:2016
 IEC 61215-2:2016
 EN 61215-2:2017
 IEC 61730-1:2016
 EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 IEC 61730-2:2016
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06